



Electric Motor Testing Tip of the Week

revolutionizing *electrical* reliability

October 8, 2007

The Seven-step Process for Basic Electrical Troubleshooting

Step five of the seven-step troubleshooting approach is *Correcting/Repairing the Component*. Correcting/Repairing the component identified as damaged can range from simple adjustments to a complete component replacement. For the boiler feed pumps discussed throughout this series of tips the technicians found that one motor had bent/damaged rotor bars as well as other related damages. Large rotors are often repaired and returned to service. However, consideration must be given to the cost comparison of replacement vs. repair.

To read more about this step and see it applied to a boiler feed pump example, read the Basic Electrical Troubleshooting document at <http://www.pdma.com/PDF/Articles/Troubleshooting.pdf>.

You are invited to submit an Electric Motor Testing Tip of your own and receive a free PdMA mug or hat if we publish it! Contact Lou at 813-621-6463 ext. 126 or lou@pdma.com.

Copyright 2007 PdMA Corporation. All rights reserved. The PdMA Tip of the Week is produced by PdMA. PdMA shall not be liable for any errors or delays in the content, or for any actions taken in reliance thereon.