



Tip Of The Week

February 20, 2012

High-Potential Testing...How Much is Enough?

According to EASA AR-100-2010, DC High-Potential testing of new stator windings from AC induction machines rated above 0.5 HP should be performed at 1700v + 3.4 times the rated voltage of the machine. Remember, this voltage test value is for a "new winding". For a post installation acceptance/QA test of the entire assembly, it is recommended that test voltage not exceed 80% of the new winding test. Once a motor has been reconditioned it is recommended that the test voltage not exceed 65% of the new winding test. And finally, for motors in service that have not been reconditioned, an insulation test should be performed rather than a high-potential test.

You are invited to submit an Electric Motor Testing Tip of your own and receive a free PdMA mug or hat if we publish it! Contact Lou at 813-621-6463 ext. 126 or lou@pdma.com.

Copyright 2012 PdMA Corporation. All rights reserved. The PdMA Tip of the Week is produced by PdMA. PdMA shall not be liable for any errors or delays in the content, or for any actions taken in reliance thereon.